

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

At the time of this inspection, lightbulbs out were observed in the following rooms: 33,30,29,26,25,99B,40,122,082,085,094,097,067 and 065. Replace lightbulbs out.

At the time of this inspection, ceiling tiles with water marks were observed at rooms: 33,30,29,26 and 38. Replace ceiling tiles.

At the time of this inspection, the restroom inside room 25 was observed with possible Biological-Grow. Repair Ceiling.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #7. Heating, Ventilation, A/C Standards

At the time of this inspection, the A/C vent at the following restrooms were observed rusted: 33,30,099C, and 099B. Replace A/C vents.

CODE REFERENCE: 7. Heating, Ventilation, A/C Standards. 5(14)(b)(12) SREF. Heating/Ventilation/Air Conditioning systems shall be operational. The systems shall maintain design temperatures of at least 78° F in the summer and 68° F in the winter; and shall provide adequate humidity control. There shall be no signs of mold or mildew on carpet or walls in or around the HVAC system or toilet rooms. 5(16)(a) SREF. All occupied rooms and other rooms where odors or contaminants are generated shall be provided with ventilation.

Inspection Conducted By: Pedro Hernandez Bastidas (60752)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 12/8/2023

Inspector Signature:

A stylized signature of Pedro Hernandez Bastidas.

Client Signature:

A stylized signature of Robert Renick.