STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT

Facility Information

RESULT: Unsatisfactory

Permit Number: 13-51-07952
Name of Facility: Robert Renick Education Ctr.
Address: 2201 NW 207 Street
City, Zip: Miami 33056

Type: Public Schools
Owner: MDCPS
Person In Charge: Aisha V. Marrero Phone: 305-624-1171
PIC Email: pr8151@dadeschools.net

Correct By: by 8:00 AM
Re-Inspection Date: 8/12/2026

Inspection Information

Purpose: Routine
Inspection Date: 6/23/2026

Begin Time: 10:45 AM
End Time: 11:30 AM

Additional Information

FEMALES 15
MALES 38

CENSUS 53

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION
IN 1. School Site
IN 2. Playground, Equip & Athletic Fields*
IN 3. Athletic & Playground Equipment
BUILDING CONST/MAINT.
IN 4. Construction
OUT 5. Maintenance & Repair
IN 6. Lighting Standards
IN 7. Heating, Ventilation, A/C Standards
IN 8. Natural Ventilation
IN 9. Mechanical Ventilation
SANITARY FACILITIES
IN 10. Provided/Accessible/Separation
IN 11. Group Toilet Rooms
IN 12. Toilet Facilities
IN 13. Handwashing Facilities
IN 14. Soap Dispensers
IN 15. Shower Facilities
IN 16. Showers Water Temperatures
WATER SUPPLY
IN 17. Approved Source
IN 18. Drinking Fountains
LIQUID WASTE & WASTE WATER
IN 19. Sewage Disposal
IN 20. Solid Waste
PEST CONTROL
IN 21. Pest Control
SAFETY
IN 22. First Aid Kit
DIAPER CHANGING STATION
IN 23. Sanitizers
IN 24. Changing Station & Mats
IN 25. Hand Sink
IN 26. Garbage Can
ANIMAL HEALTH & SAFETY
IN 27. Animal Maintenance/Aggressive
DORM/RESIDENTIAL FACILITIES
IN 28. Maintenance/Complaint
IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occuring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT

General Comments

Summer term in session

Unsatisfactory Inspection

-Observed signs of water intrusion in the facility, find the source of water filtration. clean and sanitize walls.

-Observed signs of biological growth in walls, find the source of water filtration. clean and sanitize walls.

Email Address(es): pr8151@dadeschools.net;
wcabrera@dadeschools.net;
mwertz@dadeschools.net;
ipalacio@dadeschools.net;
miriamg@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair
At the time of inspection observed roof water leak near active water leak by classroom # 059. find the source of water filtration. clean and sanitize walls

At the time of inspection observed biological growth outdoor corridors of walls near classroom # 059. find the source of water filtration. clean and sanitize walls

At the time of inspection observed biological growth outdoor walls of classroom #047 find the source of water filtration, clean and sanitize walls

At the time of inspection observed in classroom #047 with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom # 33 with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom # 33 closet with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom # 30 with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom # 30 closet with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom # 26 with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom #26 closet with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

At the time of inspection observed in classroom # 22 with water-stained ceiling tiles. Find the source of water filtration, and replace ceiling tiles

At the time of inspection observed in classroom # 22 closet with water-stained ceiling tiles. Find the source of water filtration and replace ceiling tiles.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT

Inspection Conducted By: Alexander Olaya (67699)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Aisha V. Marrero
Date: 6/23/2026

Inspector Signature:

Client Signature: