STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT

Facility Information

RESULT: Unsatisfactory

Permit Number: 13-51-07952
Name of Facility: Robert Renick Education Ctr.
Address: 2201 NW 207 Street
City, Zip: Miami 33056

Type: Public Schools
Owner: MDCPS
Person In Charge: Aisha V. Marrero Phone: 305-624-1171
PIC Email: pr8151@dadeschools.net

Correct By: by 8:00 AM
Re-Inspection Date: 12/11/2026

Inspection Information

Purpose: Reinspection
Inspection Date: 10/23/2026

Begin Time: 10:50 AM
End Time: 11:05 AM

Additional Information

FEMALES 19
MALES 39

CENSUS 58

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

	SCHOOL SANITATION	11. Group Toilet Rooms	21. Pest Control
	1. School Site	12. Toilet Facilities	SAFETY
	2. Playground, Equip & Athletic Fields*	13. Handwashing Facilities	22. First Aid Kit
	3. Athletic & Playground Equipment	14. Soap Dispensers	DIAPER CHANGING STATION
	BUILDING CONST/MAINT.	15. Shower Facilities	23. Sanitizers
	4. Construction	16. Showers Water Temperatures	24. Changing Station & Mats
OUT	5. Maintenance & Repair	WATER SUPPLY	25. Hand Sink
	6. Lighting Standards	17. Approved Source	26. Garbage Can
	7. Heating, Ventilation, A/C Standards	18. Drinking Fountains	ANIMAL HEALTH & SAFETY
	8. Natural Ventilation	LIQUID WASTE & WASTE WATER	27. Animal Maintenance/Aggressive
	9. Mechanical Ventilation	19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
	SANITARY FACILITIES	20. Solid Waste	28. Maintenance/Complaint
	10. Provided/Accessible/Separation	PEST CONTROL	29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occuring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT

General Comments

Unsatisfactory reinspection

-Observed signs of biological growth in walls by corridor near classrooms #59 and # 47, find and repair the source of water filtration, clean and sanitize walls.

Email Address(es): pr8151@dadeschools.net;
wcabrera@dadeschools.net;
mwertz@dadeschools.net;
ipalacio@dadeschools.net;
miriamg@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair
At the time of inspection observed biological growth outdoor corridors of walls near classroom # 059 and #047. find the source of water filtration. clean and sanitize walls (Repeat violation 9/25/2026)

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Alexander Olaya (67699)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Aisha V. Marrero
Date: 10/23/2026

Inspector Signature:

Client Signature: