

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

At the time of this inspection, ceiling tiles with water marks were observed at room: 022,030,084,038 and 040. Replace ceiling tiles.

At the time of this inspection, a hole in the wall was observed at room 040 near to the teacher desk. Repair wall.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

At the time of this inspection, lightbulbs out were observed at rooms: 030, Media Center,085,094 and 042. Replace lightbulbs.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #13. Handwashing Facilities

At the time of this inspection, the handwashing sink at room 040 was observed out service. Repair or replace handwashing sink.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Pedro Hernandez Bastidas (60752)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 11/1/2022

Inspector Signature:

Handwritten signature of Pedro Hernandez Bastidas.

Client Signature:

Handwritten signature of Robert Renick.